Information about your Water

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what is contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call Shauna Johnson at 785-890-4500.

The sources of drinking water (both tap water and bottled water) including rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land and through the ground, it dissolves naturally occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Source of your Water

The City of Goodland has authority for the placement of eleven (11) groundwater wells. In 2022, nine (9) wells produced water. The source water assessment has been completed by the State, which helps the City identify possible sources of well contamination. The well depths for Wells 3 through 8, 10 and 12 average 290-300 feet in depth. Wells 9 and 11 average 350 feet in depth. All of the wells receive their water from the Ogallala Aquifer.

Contaminants that may be present in source water before we treat it include.

<u>Microbial contaminants</u>, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

<u>Inorganic contaminants</u>, such as salts and metals, which can be natural occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas productions, mining or farming. <u>Pesticides and herbicides</u>, which may come from a variety of sources such as storm water run-off agriculture, and residential uses. <u>Radioactive contaminants</u>, which can be naturally occurring or the result of mining activity.

<u>Organic contaminants</u>, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum and can also come from gas stations, urban storm water run-off and septic systems.

Water Conservation Tips

- Δ Wash your fruits and vegetables in a pan instead of running water.
- Δ Upgrade older toilets with water efficient models.
- Δ Share water tips with friends.
- Δ When cleaning fish tanks, give the nutrient-rich water to your plants.
- Δ Drop your tissue in the trash instead of flushing it.
- Δ Wash your pets outdoors in an area of your lawn that needs water.
- Δ Apply water only as fast as the soil can absorb it.
- Δ Avoid watering between 12:00 p.m. to 5:00 p.m.
- $\underline{\Delta}$ When you save water, you save money on your utility bills too.

Message from the EPA

*Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by call the EPA's Safe Drinking Water Hot line (800-426-4791). *Some people may be more vulnerable to contaminates in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from a health care provider. *EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants and potential health effects are available by calling the Safe Drinking Water Hot line 800-426-4791.

General Information

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system is required to test a minimum of five samples per month in accordance with the Revised Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease causing bacteria. When Coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public .

The tables on the following page list all of the drinking water contaminants. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1-December 31, 2024. The State requires the City to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

The bottom line is that the water that is provided to you is safe.



Consumer Confidence Report 2025

Covering Calendar Year 2024



Information about Water System

* Water is a precious commodity with which we need to take great measures to be resourceful and conserve what is provided to each of us. Please take the time to look over the annual water quality report for 2024.

Included are details about where the water comes from, how it it treated, what is contains and how it compares to standards set forth by regulatory agencies. It contains vital information about your drinking water.

* This report is publish in part because of amendments to the Safe Drinking Water Act, which requires all public water systems to issue such reports on an annual basis.

* Each day, City of Goodland employees work hard to make sure that the water delivered to our customers meets or exceeds all regulatory requirements. To maintain high water quality, the staff collects samples in accordance with all State and Federal requirements.

* The Water/Sewer Superintendent is Neal Thornburg. Other staff members include Timothy Scheck, Brandon Kenny, Barney Wagner and Sam Isham.

* City Commission meetings are on the 1st and 3rd Mondays of each month at 5:00 p.m. MST at 204 W 11th St.

Terms and Abbreviations

Maximum Contaminant Level Goal (MCLG) - the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL) - the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Action Level (AL) –The concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Picocuries per Lliter (pCi/L) – a measure of the radioactivity in water

Secondary Maximum Contaminant Level (SMCL - recommended level for a contaminant that is not regulated and has no MCL.

<u>Treatment Technique (TT)</u> - a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL) – the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND) - lab analysis indicates that the contaminant is not present.

Millirems per Year (mrem/yr) - measure of radiation absorbed by the body. Monitoring Period Average (MPA) - An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA) - an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA) – Average of sample

analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Parts per Millon (ppm) – or milligrams per liter (mg/l) Parts per Billion (ppb) – or micrograms per liter (ug/l)

Lead and Cooper Information

No Violations occurred in the Calendar Year 2024

**THERE IS NO SAFE LEVEL OF LEAD IN DRINKING WATER. Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreased in IQ and attention span. Lead experience can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased rise of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems. **Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Goodland is responsible for providing high guality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing You can take responsibility by identifying and removing lead material within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institutes accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the City of Goodland at 785-890-4500. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at http://www.eap.gov/safew ater/lead

The Revised Lead and Copper Rule requires water systems to develop and maintain a Service Line Inventory. The service lien is the underground pipe that supplies your home or building with water. To view the Service Line Inventory, which list the material type for your location you may view the inventory at the <u>City of Goodland – 204 W 11th</u>.

Testing Results for City of Goodland

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
ARSENIC	02/12/2024	2.3	2.3	ppb	10	0	Erosion of natural deposits
BARIUM	02/12/2024	0.11	0.11	ppm	2	2	Discharge from metal refineries
CHROMINUM	02/12/2024	1.2	1.2	ppb	100	100	Discharge from steel and pulp mills
FLUORIDE	02/12/2024	1.4	1.4	ppm	4	4	Natural deposits; water additive which promotes strong teeth.
NITRATE	03/18/2024	8.9	8.9	ppm	10	10	Runoff from fertilizer use
SELENIUM	02/08/2021	6.8	6.8	ppb	50	50	Erosion of natural deposits

Secondary Contaminants-Non-Health Based Contaminants-No Federal Maximum Contaminant Level(MCL) Established	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	02/12/2024	170	170	MG/L	300
CALCIUM	02/12/2024	49	49	MG/L	200
CHLORIDE	02/12/2024	38	38	MG/L	250
CONDUCTIVITY@25 C UMHOS/CM	02/12/2024	520	520	UMHO/CM	1500
CORROSIVITY	02/12/2018	0.05	0.05	LANG	0
HARDNESS, TOTAL (AS CAC03)	02/12/2024	190	190	MG/L	400
MAGNESIUM	02/12/2024	17	17	MG/L	150
РН	02/12/2024	7.8	7.8	PH	8.5
POTASSIUM	02/12/2024	4.7	4.7	MG/L	100
SILICA	02/12/2024	53	53	MG/L	50
SODIUM	02/12/2024	37	37	MG/L	100
SULFATE	02/12/2024	29	29	MG/L	250
TDS	02/12/2024	350	350	MG/L	500
ZINC	02/12/2024	0.029	0.029	MG/L	5

Disinfection Byproducts	Monitoring Period	Highest RAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOCETIC ACIDS (HAA5)	2024	6	6	ppb	60	0	By-product of drinking H2O disinfection
TTHM	2024	25	25	ppb	80	0	By-product of drinking water chloration

Chlorine/Chloramines Maxium Disinfection Level					MPA Units	RAA	RAA Units	
2024-2024					MG/L	1.3	MG/L	
Lead and Copper	Monitoring Period	90 th Percentile	Range (Iow/high)	Unit AL		Sites Ov AL	er Typical Source	
COPPER, FREE	2022-2024	0.19	0.011 - 0.2	Ppm	1.3	0	Corrosion of household plumbing	
LEAD	2022-2024	3.1	0 - 6.5	ppb	15	1	Corrosion of household plumbing	